U.S. Department of Labor
Occupational Safety and Health Administration
299 Cherry Hill Road
Suite 103
Parsippany, NJ 07054
Phone: 973-263-1003 Fax: 973-299-7161

Citation and Notification of Penalty

To: James Lerie
Blade Contracting, Inc
188 Van Buren Street
Staten Island, NY 10301

Inspection Number: 331283
Inspection Date(s): 03/16/2012 - 09/14/2012
Issuance Date: 09/14/2012

Inspection Site:
837 Jersey Ave
Jersey City, NJ 07097

The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Please refer to the enclosed booklet (OSHA 3000) which outlines your rights and responsibilities and which should be read in conjunction with this form. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

Posting - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer.

Informal Conference - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period. During such an informal conference you may present any evidence or views which you believe would support an adjustment to the citation(s) and/or penalty(ies).

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of this Citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete, remove and post the Notice to Employees next to this Citation and Notification of Penalty as soon as the time, date, and place of the informal conference have been determined. Be sure to bring to the conference any and all supporting documentation of existing conditions as well as any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

Right to Contest – You have the right to contest this Citation and Notification of Penalty. You may contest all citation items or only individual items. You may also contest proposed penalties and/or abatement dates without contesting the underlying violations. **Unless you inform the Area Director in writing that you intend to contest the citation(s) and/or proposed penalty(ies) within 15 working days after receipt, the citation(s) and the proposed penalty(ies) will become a final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency.**

Penalty Payment – Penalties are due within 15 working days of receipt of this notification unless contested. (See the enclosed booklet and the additional information provided related to the Debt Collection Act of 1982.) Make your check or money order payable to "DOL-OSHA". Please indicate the Inspection Number on the remittance.

OSHA does not agree to any restrictions or conditions or endorsements put on any check or money order for less than the full amount due, and will cash the check or money order as if these restrictions, conditions, or endorsements do not exist.

Notification of Corrective Action – For each violation which you do not contest, you must provide ***abatement certification*** to the Area Director of the OSHA office issuing the citation and identified above. This abatement certification is to be provided by letter within 10 calendar days after each abatement date. Abatement certification includes the date and method of abatement. If the citation indicates that the violation was corrected during the inspection, no abatement certification is required for that item. The abatement certification letter must be posted at the location where the violation appeared and the corrective action took place or employees must otherwise be effectively informed about abatement activities. A sample abatement certification letter is enclosed with this Citation. In addition, where the citation indicates that ***abatement documentation*** is necessary, evidence of the purchase or repair of equipment, photographs or video, receipts, training records, etc., verifying that abatement has occurred is required to be provided to the Area Director.

Employer Discrimination Unlawful – The law prohibits discrimination by an employer against an employee for filing a complaint or for exercising any rights under this Act. An employee who believes that he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the U.S. Department of Labor Area Office at the address shown above.

Employer Rights and Responsibilities – The enclosed booklet (OSHA 3000) outlines additional employer rights and responsibilities and should be read in conjunction with this notification.

Notice to Employees – The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must be mailed to the U.S. Department of Labor Area Office at the address shown above and postmarked within 15 working days

(excluding weekends and Federal holidays) of the receipt by the employer of this Citation and Notification of Penalty.

Inspection Activity Data – You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of the Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at www.osha.gov. If you have any dispute with the accuracy of the information displayed, please contact this office.

NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE

An informal conference has been scheduled with OSHA to discuss the citation(s) issued on 09/14/2012. The conference will be held at the OSHA office located at 299 Cherry Hill Road, Suite 103, Parsippany, NJ 07054 on _____ at _____. Employees and/or representatives of employees have a right to attend an informal conference.

CERTIFICATION OF CORRECTIVE ACTION WORKSHEET

Inspection Number: 331283

Company Name: Blade Contracting, Inc
Inspection Site: 837 Jersey Ave, Jersey City, NJ 07097
Issuance Date: 09/14/2012

List the specific method of correction for each item on this citation in this package that does not read "Corrected During Inspection" and return to: **U.S. Department of Labor – Occupational Safety and Health Administration, 299 Cherry Hill Road, Suite 103, Parsippany, NJ 07054**

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____
_____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____
_____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____
_____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____
_____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____
_____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____
_____

I certify that the information contained in this document is accurate and that the affected employees and their representatives have been informed of the abatement.

_____ _____
Signature Date

_____ _____
Typed or Printed Name Title

NOTE: 29 USC 666(g) whoever knowingly makes any false statements, representation or certification in any application, record, plan or other documents filed or required to be maintained pursuant to the Act shall, upon conviction, be punished by a fine of not more than $10,000 or by imprisonment of not more than 6 months or both.

POSTING: A copy of completed Corrective Action Worksheet should be posted for employee review

Citation and Notification of Penalty

Company Name: Blade Contracting, Inc
Inspection Site: 837 Jersey Ave, Jersey City, NJ 07097

Citation 1 Item 1 Type of Violation: **Serious**

29 CFR 1926.452(c)(2): Frames and panels were not braced by cross, horizontal, or diagonal braces, or combination thereof, which would secure vertical members together laterally, and the cross braces were not of such length as would automatically square:

a) 837 Jersey Ave, Jersey City, NJ, - south side parking garage, 7th floor

Cross-bracing on the south side of parking garage, 7th floor was not installed on the outside of a tubular frame scaffold to ensure stability.

Violation observed on or 06/01/2012.

b) 837 Jersey Ave, Jersey City, NJ - south side parking garage, 7th floor

Cross-bracing on the south side of parking garage, 7th floor was not installed on the inside of a tubular frame scaffold to ensure stability

Violation observed on or about 06/05/2012.

c) 837 Jersey Ave, Jersey City, NJ north side parking garage, 7th floor

Cross-bracing on the north side of parking garage, 5th/6th floor was not installed on the outside of a tubular frame scaffold to ensure stability

Violation observed on or about 06/05/2012.

d) 837 Jersey Ave, Jersey City, NJ north side parking garage, 7th floor

Citation and Notification of Penalty

Company Name: Blade Contracting, Inc
Inspection Site: 837 Jersey Ave, Jersey City, NJ 07097

Cross-bracing on the tubular frame scaffold on north side of parking garage, 7th floor was not installed on the entire inside section of the tubular frame scaffold to ensure stability.

Violation observed on or about 06/06/2012.

Date By Which Violation Must be Abated: Corrected During Inspection
Proposed Penalty: $5390.00

Citation and Notification of Penalty

Company Name: Blade Contracting, Inc
Inspection Site: 837 Jersey Ave, Jersey City, NJ 07097

Citation 1 Item 2 Type of Violation: **Serious**

29 CFR 1926.502(d)(23): Personal fall arrest systems were attached to guardrail systems or to hoists:

a. 837 Jersey Ave, Jersey City, NJ south side garage, 7th floor

Employees were observed on south side, 7th floor working from a makeshift elevated platform on tubular frame scaffold while their lanyards were attached to the top guardrail of the scaffold.
Violation observed on or about 06/01/2012

b) 837 Jersey Ave, Jersey City, NJ south side garage, 7th floor

Employee was observed on south side, 7th floor working from a makeshift elevated platform constructed on a tubular frame scaffold while his lanyard was attached to top guardrail of the scaffold.
Violation observed on or about 06/05/2012

Date By Which Violation Must be Abated: Corrected During Inspection
Proposed Penalty: $3850.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

Citation and Notification of Penalty

Company Name: Blade Contracting, Inc
Inspection Site: 837 Jersey Ave, Jersey City, NJ 07097

Citation 1 Item 3 Type of Violation: **Serious**

29 CFR 1926.503(a)(1): The employer did not provide a training program for each employee who might be exposed to fall hazards:

a) 837 Jersey Ave, Jersey City, NJ - south side of building, 6th floor balcony

Employee on south side 6th floor balcony was not trained in the recognition and avoidance of unsafe condition(s). Hazards included but were not limited to falls.

Violation occurred on or about 03/16/2012.

Date By Which Violation Must be Abated: Corrected During Inspection
Proposed Penalty: $5390.00

Citation and Notification of Penalty

Company Name: Blade Contracting, Inc
Inspection Site: 837 Jersey Ave, Jersey City, NJ 07097

Citation 1 Item 4 Type of Violation: **Serious**

29 CFR 1926.1053(b)(4): Ladders were used for purposes other than the purposes for which they were designed:

a) 837 Jersey Ave, Jersey City, NJ - south side garage, 7th floor

A-frame stepladder on south side of parking garage 7th floor was being used in the closed position to access tubular frame scaffold.

Violation observed on or about 06/01/2012.

Date By Which Violation Must be Abated: Corrected During Inspection
Proposed Penalty: $3080.00

Citation and Notification of Penalty

Company Name: Blade Contracting, Inc
Inspection Site: 837 Jersey Ave, Jersey City, NJ 07097

Citation 2 Item 1 Type of Violation: **Willful**

29 CFR 1926.451(f)(14): Makeshift devices were used on top of scaffold platforms to increase the working level height of employees:

a) 837 Jersey Ave, Jersey City NJ - south side garage , 7th floor

Employees were walking/working on makeshift platforms, i.e. brick and scaffold planks to increase their working level, and were thereby exposed to fall hazards.

Violation observed on or about 06/01/2012.

b) 837 Jersey Ave, Jersey City NJ - south side garage , 7th floor

Employees were walking/working on makeshift platforms, i.e. brick and scaffold planks to increase their working level, and were thereby exposed to fall hazards.

Violation observed on or about 06/05/2012.

c) 837 Jersey Ave, Jersey City NJ - north side garage , 6th floor

Employees were walking/working on makeshift platforms, i.e. block and scaffold planks to increase their working level, and were thereby exposed to fall hazards.

Violation observed on or about 06/06/2012.

Date By Which Violation Must be Abated: Corrected During Inspection
Proposed Penalty: $53900.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

Citation and Notification of Penalty

Company Name: Blade Contracting, Inc
Inspection Site: 837 Jersey Ave, Jersey City, NJ 07097

Citation 3 Item 1 Type of Violation: **Repeat**

29 CFR 1926.451(g)(1): Employees on scaffolds more than 10 feet (3.1 m) above a lower level were not protected from falling to that lower level by fall protection established in paragraphs (g)(1)(i)-(vii) of this section:

a) 837 Jersey Ave, Jersey City, NJ - south side garage, 7th floor

Employees that were walking/working on tubular frame scaffold were not protected from fall hazards of approximately 27 feet.

Violation observed on or about 06/01/2012.

Blade Contracting, Inc., was previously cited for a violation of this Occupational Safety and Health Standard or its equivalent 29 CFR 1926.451 (g)(1)(vii) which was contained in OSHA Inspection Number 311441109, Citation Number 1, Item Number 2, with a final order issued on 11/27/2007 with respect to a workplace located at 777 United Nations Plaza, New York, NY.

Blade Contracting, Inc., was previously cited for a violation of this Occupational Safety and Health Standard or its equivalent 29 CFR 1926.451 (g)(1) which was contained in OSHA Inspection Number 313992588, Citation Number 1, Item Number 1, with a final order issued on 07/26/2010 with respect to a workplace located at 465 Washington Blvd, Jersey City, NJ.

Blade Contracting, Inc., was previously cited for a violation of this Occupational Safety and Health Standard or its equivalent 29 CFR 1926.451 (g)(1) which was contained in OSHA Inspection Number 314387010, Citation Number 1, Item Number 2, with a final order issued on 10/13/2010 with respect to a workplace located at 99 Monmouth Street, Red Bank, NJ.

Date By Which Violation Must be Abated: Corrected During Inspection
Proposed Penalty: $53900.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

Citation and Notification of Penalty

Company Name: Blade Contracting, Inc
Inspection Site: 837 Jersey Ave, Jersey City, NJ 07097

Citation 3 Item 2 Type of Violation: **Repeat**

29 CFR 1926.501(b)(1): Each employee on a walking/working surface with an unprotected side or edge which was 6 feet (1.8 m) or more above a lower level was not protected from falling by the use of guardrail systems, safety net systems, or personal fall arrest systems.

a) 837 Jersey Ave, Jersey City, NJ, South side of building

Employee working on the balcony of the 6th floor was not protected by guardrail system, safety net system, or personal fall arrest system, thereby causing employee to fall 10 feet 2 inches to the next lower level.

Violation occurred on or about 03/16/2012.

Blade Contracting, Inc., was previously cited for a violation of this Occupational Safety and Health Standard or its equivalent 29 CFR 1926.501 (b)(1) which was contained in OSHA Inspection Number 311058812, Citation Number 1, Item Number 3a, with a final order date issued on 12/21/2007 with respect to a workplace located at 50 Columbus Drive, Jersey City, NJ.

Date By Which Violation Must be Abated: Corrected During Inspection
Proposed Penalty: $10780.00

Kris Hoffman
Area Director

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration
299 Cherry Hill Road
Suite 103
Parsippany, NJ 07054
Phone: 973-263-1003 Fax: 973-299-7161

INVOICE / DEBT COLLECTION NOTICE

Company Name: **Blade Contracting, Inc**
Inspection Site: **837 Jersey Ave, Jersey City, NJ 07097**
Issuance Date: **09/14/2012**

Summary of Penalties for Inspection Number	**331283**
Citation 1, Serious	**$17710.00**
Citation 2, Willful	**$53900.00**
Citation 3, Repeat	**$64680.00**
TOTAL PROPOSED PENALTIES	**$136290.00**

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance.

OSHA does not agree to any restrictions or conditions or endorsements put on any check or money order for less than the full amount due, and will cash the check or money order as if these restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular account statement. You will not receive your original check back. The bank will destroy your original check, but will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed account, the bank will attempt to make the transfer up to 2 times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

Interest: Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

Delinquent Charges: A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

Administrative Costs: Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.

Kris Hoffman
Area Director

9/14/2012
Date