



**Citation and Notification of Penalty**

**Company Name:** Buildtronix, LLC

**Inspection Site:** 65 Morningstar Way (Lot 164), Ponte Vedra, FL 32081

**Citation 1 Item 1** Type of Violation: **Willful**

29 CFR 1926.501(b)(13): Each employee(s) engaged in residential construction activities 6 feet (1.8 m) or more above lower levels were not protected by guardrail systems, safety net system, or personal fall arrest system, nor were employee(s) provided with an alternative fall protection measure under another provision of paragraph 1926.501 (b):

a. Employees performing residential framing work at elevations of six feet or more above the ground are not protected from fall hazards by a fall protection system.

The employer fails to assure effective protection against falls as required by the standard, as demonstrated on April 16, 2015, when employees were installing framing from on the roof structure of a one-story residence at 65 Morningstar Way (Lot. 164), Ponte Vedra, Florida 32081 without fall protections and were exposed to fall hazards of 10 and 14 feet above the concrete foundation and surrounding ground.

Transformers Construction Services, Inc. previously committed a Willful violation of this standard with an 11(b) warning on October 1, 2014, when employees were installing framing from the first and second story of a residential house at 25 Molasses Court, Saint Johns, Florida 32259, which became a Final Order on March 9, 2015. (Inspection No. 997663)

Transformers Construction Services, Inc. previously committed a Willful violation of this standard with an 11(b) warning on April 10, 2014, when employees were working on a residential house at 62 Stirlingshire Court, Saint Johns, Florida, 32259, which became a Final Order on August 6, 2014. (Inspection No. 967068)

Transformers Construction Services, Inc. previously committed a Repeat violation of this standard on January 17, 2014, when employees were working on a residential house at 106 Cantley Way, Saint Augustine, Florida, 32259, which became a Final Order on April 2, 2014. (Inspection No. 955478)

Transformers Construction Services, Inc. previously committed a Repeat violation of this standard on January 15, 2014, when employees were working on a residential house at 1274 Camp Ridge Lane, Middleburg, Florida, 32068, which became a Final Order on May 5, 2014. (Inspection No. 955068)

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

**U.S. Department of Labor**  
Occupational Safety and Health Administration

**Inspection Number:** 1055972  
**Inspection Date(s):** 04/16/2015 - 04/16/2015  
**Issuance Date:** 06/26/2015



**Citation and Notification of Penalty**

**Company Name:** Buildtronix, LLC  
**Inspection Site:** 65 Morningstar Way (Lot 164), Ponte Vedra, FL 32081

---

Transformers Construction Services, Inc. previously committed a Repeat violation of this standard on October 17, 2013, when employees were working on a residential house at 95076 Lilac Drive, Fernandina Beach, Florida, 32034, which became a Final Order on November 18, 2013. (943263)

Transformers Construction Services, Inc. previously committed a Serious violation of this standard on November 21, 2011, when employees were working on a residential house at 12298 Water Tupelo Street, Jacksonville, Florida, 32226, which became a Final Order on February 1, 2012. (315481929)

To abate this violation, the employer must ensure that all employees wear appropriate fall protection or install a guardrail or safety net system when an employee works above 6 feet off the surface. Pursuant to 29 CFR 1903.19, the employer must submit documents describing the steps it is taking to ensure compliance, including an explanation of how these steps protect its employees from fall hazards.

---

<b>Date By Which Violation Must be Abated:</b>	<b>Corrected During Inspection</b>
<b>Proposed Penalty:</b>	<b>\$70000.00</b>

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



**Citation and Notification of Penalty**

**Company Name:** Buildtronix, LLC  
**Inspection Site:** 65 Morningstar Way (Lot 164), Ponte Vedra, FL 32081

**Citation 2 Item 1** Type of Violation: **Repeat**

29 CFR 1926.102(a)(1): Eye and face protective equipment were not used when machines or operations presented potential eye or face injury from physical, chemical, or radiation agents:


a. On or about April 16, 2015, at the east and south side of the roof frame, employees operating Hitachi pneumatic nail guns to perform bracing work were not wearing eye protection, exposing them to being struck by flying debris or nails.

Transformers Construction Services, Inc. was previously cited for a violation of this occupational safety and health standard or its equivalent standard, which was contained in OSHA inspection number 967068, citation number 01, item number 001 and was affirmed as a final order on August 6, 2014, with respect to a workplace located at 62 Stirlingshire Court, Saint Johns, Florida, 32259.

**ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM**

Date By Which Violation Must be Abated:  
Proposed Penalty:

07/02/2015  
\$6160.00



**Brian J. Sturtecky**  
Area Director

**U.S. Department of Labor**  
Occupational Safety and Health Administration  
1851 Executive Center Drive  
Suite 227  
Jacksonville, FL 32207  
Phone: 904-232-2895 Fax: 904-232-1294



## INVOICE / DEBT COLLECTION NOTICE

---

**Company Name:** Buildtronix, LLC  
**Inspection Site:** 65 Morningstar Way (Lot 164), Ponte Vedra, FL 32081  
**Issuance Date:** 06/26/2015

<b>Summary of Penalties for Inspection Number</b>	<b>1055972</b>
<b>Citation 1, Willful</b>	<b>\$70000.00</b>
<b>Citation 2, Repeat</b>	<b>\$6160.00</b>
<b>TOTAL PROPOSED PENALTIES</b>	<b>\$76160.00</b>

---

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance. You can also make your payment electronically on [www.pay.gov](http://www.pay.gov). On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type "OSHA" and click Go. From the results, click on **OSHA Penalty Payment Form**. The direct link is <https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>. You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will cash the check or money order as if these restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular account statement. You will not receive your original check back. The bank will destroy your original check, but will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed

account, the bank will attempt to make the transfer up to 2 times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

**Interest:** Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

**Delinquent Charges:** A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

**Administrative Costs:** Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.

  
\_\_\_\_\_  
Brian J. Sturtecky  
Area Director

6/24/2015  
\_\_\_\_\_  
Date