



**Citation and Notification of Penalty**

**Company Name:** Loos & Company, Inc.  
**Inspection Site:** 1 Cable Road, Pomfret, CT 06258

---

The alleged violations below have been grouped because they involve similar or related hazards that may increase the potential for illness or injury resulting from an accident.

**Citation 1 Item 1a** Type of Violation: **Serious**

29 CFR 1910.333(a)(1): Live parts to which an employee could be exposed were not deenergized before the employee worked on or near them:

Plant: Approximately once a month, employees tied into the load side of circuit breakers that were located in live 120/208 volt panelboards.

**Specific Abatement Documentation is Required**

Date By Which Violation Must be Abated:	11/03/2011
Proposed Penalty:	\$ 7000.00



**Citation and Notification of Penalty**

Company Name: Loos & Company, Inc.  
Inspection Site: 1 Cable Road, Pomfret, CT 06258

---

**Citation 1 Item 1b** Type of Violation: **Serious**


29 CFR 1910.335(a)(2)(i): When working near exposed energized conductors or circuit parts, each employee did not use insulated tools or handling equipment when the tools or handling equipment might have made contact with such conductors or parts:

Plant: Employees who made live tie-in's to circuit breaker in 120/208 volt panelboards used regular, non-insulated, non-voltage rated tools.

**Specific Abatement Documentation is Required**

Date By Which Violation Must be Abated:

11/03/2011

  
PAUL MANGIAFICO  
Area Director