

U.S. Department of Labor

Occupational Safety and Health Administration
701 Route 73 South
Building 2, Suite 120
Marlton, NJ 08053
Phone: 856-596-5200 Fax: 856-596-5201



Citation and Notification of Penalty

To:
E.I. DuPont DeNemours Incorporated Chambers
Works
and its successors
Rt 130 & Canal Rd
Deepwater, NJ 08023

Inspection Number: 977332
Inspection Date(s): 05/19/2014 - 05/19/2014
Issuance Date: 11/17/2014

Inspection Site:
Rt 130 & Canal Rd
Deepwater, NJ 08023

The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty **you either call to schedule an informal conference (see paragraph below) or** you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Please refer to the enclosed booklet (OSHA 3000) which outlines your rights and responsibilities and which should be read in conjunction with this form. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

Posting - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer.

Informal Conference - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period. During such an informal conference you may present any evidence or views which you believe would support an adjustment

to the citation(s) and/or penalty(ies).

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of this Citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete, remove and post the Notice to Employees next to this Citation and Notification of Penalty as soon as the time, date, and place of the informal conference have been determined. Be sure to bring to the conference any and all supporting documentation of existing conditions as well as any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

Right to Contest – You have the right to contest this Citation and Notification of Penalty. You may contest all citation items or only individual items. You may also contest proposed penalties and/or abatement dates without contesting the underlying violations. **Unless you inform the Area Director in writing that you intend to contest the citation(s) and/or proposed penalty(ies) within 15 working days after receipt, the citation(s) and the proposed penalty(ies) will become a final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency.**

Penalty Payment – Penalties are due within 15 working days of receipt of this notification unless contested. (See the enclosed booklet and the additional information provided related to the Debt Collection Act of 1982.) Make your check or money order payable to “DOL-OSHA”. Please indicate the Inspection Number on the remittance. You can also make your payment electronically on www.pay.gov. On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type “OSHA” and click Go. From the results, click on **OSHA Penalty Payment Form**. The direct link is:

<https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>.

You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$50,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will process the payments as if these restrictions or conditions do not exist.

Notification of Corrective Action – For each violation which you do not contest, you must provide *abatement certification* to the Area Director of the OSHA office issuing the citation and identified above. This abatement certification is to be provided by letter within 10 calendar days after each abatement date. Abatement certification includes the date and method of abatement. If the citation indicates that the violation was corrected during the inspection, no abatement certification is required for that item. The abatement certification letter must be posted at the location where the violation appeared and the corrective action took place or employees must otherwise be effectively informed about abatement activities. A sample abatement certification letter is enclosed with this Citation. In addition, where the citation indicates that *abatement documentation* is necessary, evidence of the purchase or repair of equipment, photographs or video, receipts, training records, etc., verifying that abatement has occurred is required to be provided to the Area Director.

Employer Discrimination Unlawful – The law prohibits discrimination by an employer against an employee for filing a complaint or for exercising any rights under this Act. An employee who believes that he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the U.S. Department of Labor Area Office at the address shown above.

Employer Rights and Responsibilities – The enclosed booklet (OSHA 3000) outlines additional employer rights and responsibilities and should be read in conjunction with this notification.

Notice to Employees – The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must be mailed to the U.S. Department of Labor Area Office at the address shown above and postmarked within 15 working days (excluding weekends and Federal holidays) of the receipt by the employer of this Citation and Notification of Penalty.

Inspection Activity Data – You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of the Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at www.osha.gov. If you have any dispute with the accuracy of the information displayed, please contact this office.



NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE

An informal conference has been scheduled with OSHA to discuss the citation(s) issued on 11/17/2014. The conference will be held by telephone or at the OSHA office located at 701 Route 73 South, Building 2, Suite 120, Marlton, NJ 08053 on _____ at

_____. Employees and/or representatives of employees have a right to attend an informal conference.

CERTIFICATION OF CORRECTIVE ACTION WORKSHEET

Inspection Number: 977332

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023
Issuance Date: 11/17/2014

List the specific method of correction for each item on this citation in this package that does not read "Corrected During Inspection" and return to: **U.S. Department of Labor – Occupational Safety and Health Administration, 701 Route 73 South, Building 2, Suite 120, Marlton, NJ 08053**

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

I certify that the information contained in this document is accurate and that the affected employees and their representatives have been informed of the abatement.

Signature

Date

Typed or Printed Name

Title

NOTE: 29 USC 666(g) whoever knowingly makes any false statements, representation or certification in any application, record, plan or other documents filed or required to be maintained pursuant to the Act shall, upon conviction, be punished by a fine of not more than \$10,000 or by imprisonment of not more than 6 months or both.

POSTING: A copy of completed Corrective Action Worksheet should be posted for employee review



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 1 Item 1 Type of Violation: **Serious**

29 CFR 1910.119(d)(3)(i)(B): Written process safety information pertaining to equipment in the process did not include piping and instrumentation diagrams (P&IDs).

a) PC West Building 1205: The employer did not ensure that the written process safety information included all the necessary information pertaining to the equipment in the process when their P&ID DW32116 incorrectly depicted the restricting orifice from TC-156 as being located after the valves on the discharge side of P-1138. The restricting orifice was actually located before the valves, on or about 5/19/14.

b) PC West Building 1205: The employer did not ensure that the written process safety information included all the necessary information pertaining to the equipment in the process when their P&ID DW32116 incorrectly identified the pipe code for line number P7 as SP65OU when it should have been L1N655, on or about 5/19/14.

NOTE: THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT CERTIFICATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

Date By Which Violation Must be Abated: 12/12/2014
Proposed Penalty: \$5,500.00

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 977332
Inspection Date(s): 05/19/2014 - 05/19/2014
Issuance Date: 11/17/2014



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 1 Item 2 Type of Violation: **Serious**

29 CFR 1910.119(d)(3)(i)(H): Process safety information pertaining to the equipment in the process did not include the safety systems (e.g., interlocks, detection or suppression systems):

a) PC West 1205 building: The employer's process safety information did not include the design and design basis for safety systems, such as, but not limited to, the 1205-FA31 flame arrestor located on scrubber SB 166, on or about 5/19/14.

NOTE: THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT CERTIFICATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

Date By Which Violation Must be Abated:
Proposed Penalty:

12/12/2014
\$5,500.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 977332
Inspection Date(s): 05/19/2014 - 05/19/2014
Issuance Date: 11/17/2014



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 1 Item 3 Type of Violation: **Serious**

29 CFR 1910.119(e)(3)(vii): The process hazard analysis did not address a qualitative evaluation of a range of the possible safety and health effects of failure of controls on employees in the workplace.

a) PC West 1205 Building: In the employer's 2009 PHA, the What If checklist was incomplete and did not address the possible employee safety and health effects of the failure of process controls such as, but not limited to, loss of agitation in A206 or failure to detect TC2 high level alarm, on or about 5/19/14.

NOTE: THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT CERTIFICATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

Date By Which Violation Must be Abated:
Proposed Penalty:

12/12/2014
\$5,500.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 1 Item 4 Type of Violation: **Serious**

29 CFR 1910.119(f)(3): The operating procedures were not reviewed as often as necessary to assure that they reflect current operating practice, including changes that result from changes in process chemicals, technology, and equipment, and changes to facilities:

- a) PC West 1205 Building: Operating procedure 60 was not updated to reflect the removal of the HFA monitors from the 1205 building, on or about 5/19/14.
- b) PC West 1205 Building: Operating procedure 60 was not updated to reflect the designation of hazardous materials technicians. Building operators were incorrectly listed as hazardous materials technicians, on or about 5/19/14.

NOTE: THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT CERTIFICATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

Date By Which Violation Must be Abated: 12/12/2014
Proposed Penalty: \$5,500.00

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 977332
Inspection Date(s): 05/19/2014 - 05/19/2014
Issuance Date: 11/17/2014



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 1 Item 5 Type of Violation: **Serious**

29 CFR 1910.119(j)(2): The employer did not establish written procedures to maintain the on-going integrity of process equipment:

a) PC West 1205 Building: The employer did not establish written procedures to maintain the on-going integrity of HFA DOT 106A and 110A cylinders as recommended by RAGAGEP, such as, but not limited to, Department of Transportation 49 CFR Part 180, on or about 5/19/14.

NOTE: THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT CERTIFICATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

Date By Which Violation Must be Abated:
Proposed Penalty:

12/12/2014
\$5,500.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 1 Item 6 Type of Violation: **Serious**

29 CFR 1910.119(j)(5): The employer did not correct deficiencies in equipment that were outside acceptable limits (defined by the process safety information on paragraph (d) of this section) before use:

a) Diamines nitrators: Employees were exposed to a pipeline containing 12% aqueous ammonia subject to vibration caused by a metering pump, which could have resulted in chemical burns in the event of a leak, on or about 5/20/14.

NOTE: THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT CERTIFICATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

Date By Which Violation Must be Abated:
Proposed Penalty:

12/12/2014
\$3,300.00

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 977332
Inspection Date(s): 05/19/2014 - 05/19/2014
Issuance Date: 11/17/2014



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 1 Item 7 Type of Violation: **Serious**

29 CFR 1910.119(l)(1): The employer did not implement written procedures to manage changes to process chemicals, technology, equipment, and procedures, and changes to facilities that affect a covered process:

a) PC West 1205 building: The employer did not implement a management of change form for the 2008 discontinuation of the 12 HFA monitors in the 1205 building, on or about 5/19/14.

NOTE: THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT CERTIFICATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

Date By Which Violation Must be Abated:
Proposed Penalty:

12/12/2014
\$5,500.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 1 Item 8 Type of Violation: **Serious**

29 CFR 1910.119(o)(4): The employer did not promptly determine and document an appropriate response to each of the findings of the compliance audit, and document that deficiencies had been corrected:

a) PC West 1205 Building: The employer did not promptly determine and document an appropriate response to the 2010 compliance audit finding F016. The finding suggested that all critical equipment be included in a list for testing and inspection. The assigned completion date is 1/31/15, which is an unreasonable amount of time for the work required, on or about 5/19/14.

b) PC West 1205 Building: The employer did not promptly determine and document an appropriate response to the 2013 compliance audit finding F013. The finding suggested that the design basis for the PC West area electrical classifications be developed and documented. Flammable hydrogen gas is utilized in the process in this area. The assigned completion date is 7/31/15, which is an unreasonable amount of time for the work required, on or about 5/19/14.

c) PC West 1205 Building: The employer did not promptly determine and document an appropriate response to the 2013 compliance audit finding F024. The finding suggested that the conditions requiring emergency shutdown be added to operating procedures. The assigned completion date is 11/30/16, which is an unreasonable amount of time for the work required, on or about 5/19/14.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 977332
Inspection Date(s): 05/19/2014 - 05/19/2014
Issuance Date: 11/17/2014



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

d) PC West 1205 Building: The employer did not promptly determine and document an appropriate response to the 2013 compliance audit finding F027. The finding suggested that the operating procedures be updated to include guidance on what actions to take if a safety interlock demand and activation occurs. The assigned completion date is 11/30/16, which is an unreasonable amount of time for the work required, on or about 5/19/14.

NOTE: IN ADDITION TO ABATEMENT CERTIFICATION, THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT DOCUMENTATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	12/12/2014
Proposed Penalty:	\$7,000.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 2 Item 1 Type of Violation: **Repeat**

29 CFR 1910.119(e)(3)(i): The PHA did not address the hazards of the process.

a) PC West 1205 Building: The process hazard analysis for the HFIP process did not address the hazards related to the storage of the HFA one ton cylinders in the Marcotte Mall, transportation of the HFA one ton cylinders via forklift from the mall to the HFA shed and the connection of the HFA one ton cylinders to the process, on or about 5/19/14.

NOTE: IN ADDITION TO ABATEMENT CERTIFICATION, THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT DOCUMENTATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

E.I. DUPONT DENEMOURS INCORPORATED; WAS PREVIOUSLY CITED FOR A VIOLATION OF THIS OCCUPATIONAL SAFETY AND HEALTH STANDARD, ITS EQUIVALENT, OR ESSENTIALLY SIMILAR STANDARD, 29 CFR 1910.119(e)(3)(i) WHICH WAS CONTAINED IN OSHA INSPECTION NUMBER 313371924 CITATION NUMBER 1, ITEM NUMBER 3, AND WAS AFFIRMED AS FINAL ORDER ON 8/9/10, WITH RESPECT TO A WORKPLACE LOCATED AT 901 WEST DUPONT AVENUE BELLE WEST VIRGINIA 25015.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	12/12/2014
Proposed Penalty:	\$38,500.00



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 2 Item 2 Type of Violation: **Repeat**

29 CFR 1910.119(j)(4)(i): The employer did not perform inspection and tests on process equipment:

a) PC West 1205 Building: The employer did not conduct appropriate inspections and tests on HFA DOT 106A and 110A cylinders as recommended by RAGAGEP, such as, but not limited to, Department of Transportation 49 CFR Part 180, on or about 5/19/14.

NOTE: IN ADDITION TO ABATEMENT CERTIFICATION, THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT DOCUMENTATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

E.I. DUPONT DENEMOURS INCORPORATED; WAS PREVIOUSLY CITED FOR A VIOLATION OF THIS OCCUPATIONAL SAFETY AND HEALTH STANDARD, ITS EQUIVALENT, OR ESSENTIALLY SIMILAR STANDARD, 29 CFR 1910.119(j)(4)(i) WHICH WAS CONTAINED IN OSHA INSPECTION NUMBER 313371924 CITATION NUMBER 1, ITEM NUMBER 2, AND WAS AFFIRMED AS FINAL ORDER ON 8/9/10, WITH RESPECT TO A WORKPLACE LOCATED AT 901 WEST DUPONT AVENUE BELL WEST VIRGINIA 25015.

E.I. DUPONT DENEMOURS INCORPORATED; WAS PREVIOUSLY CITED FOR A VIOLATION OF THIS OCCUPATIONAL SAFETY AND HEALTH STANDARD, ITS EQUIVALENT, OR ESSENTIALLY SIMILAR STANDARD, 29 CFR 1910.119(j)(4)(i) WHICH WAS CONTAINED IN OSHA INSPECTION NUMBER 315723312 CITATION NUMBER 1, ITEM NUMBER 7A, AND WAS AFFIRMED AS FINAL ORDER ON 1/2/13, WITH RESPECT TO A WORKPLACE LOCATED AT STATE HIGHWAY 347 BEAUMONT TEXAS 77705.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:	12/12/2014
Proposed Penalty:	\$38,500.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023

Citation 3 Item 1 Type of Violation: **Other-than-Serious**

29 CFR 1910.119(e)(5): The employer did not establish a system to promptly address the PHA team's findings and recommendations:

a) PC West 1205 Building: The employer did not develop a system to promptly address the findings and recommendations from the 2009 PHA. Several items, such as, but not limited to those listed below, were found to still be pending, on or about 5/19/14:

- Create a PM to inspect or replace check valves annually to ensure adequate backflow (page 2 system 1 DW49060)
- Check that the PRD is adequate for this case (page 3 system 1 DW49060)
- Determine how the system will be pressure tested before starting up from maintenance activities or other activities where the equipment was opened (page 7 system 1 DW49060)
- The interlock action is not accurate per OP No. 96 SB 166 Interlock Test Procedures. The interlock does not block the C 390 vent to SB 166. (page 2 appendix 14 SOL/SOC documentation)
- The interlock action is not accurate for 1822PC interlock action (page 2 appendix 14 SOL/SOC documentation)

NOTE: THE EMPLOYER IS REQUIRED TO SUBMIT ABATEMENT CERTIFICATION FOR THIS ITEM. FAILURE TO COMPLY WILL RESULT IN AN ADDITIONAL PENALTY OF \$1000.00 IN ACCORDANCE WITH 29 CFR 1903.19.

Date By Which Violation Must be Abated:

12/12/2014

Proposed Penalty:

\$0.00

A handwritten signature in black ink, appearing to read "Paula Dixon-Roderick". The signature is written in a cursive style and is positioned above a horizontal line.

Sr Paula Dixon-Roderick
Area Director

U.S. Department of Labor
Occupational Safety and Health Administration
701 Route 73 South
Building 2, Suite 120
Marlton, NJ 08053
Phone: 856-596-5200 Fax: 856-596-5201



INVOICE / DEBT COLLECTION NOTICE

Company Name: E.I. DuPont DeNemours Incorporated Chambers Works
Inspection Site: Rt 130 & Canal Rd, Deepwater, NJ 08023
Issuance Date: 11/17/2014

Summary of Penalties for Inspection Number	977332
Citation 1, Serious	\$43,300.00
Citation 2, Repeat	\$77,000.00
Citation 3, Other-than-Serious	\$0.00
TOTAL PROPOSED PENALTIES	\$120,300.00

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance. You can also make your payment electronically on www.pay.gov. On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type "OSHA" and click Go. From the results, click on **OSHA Penalty Payment Form**. The direct link is <https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>. You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$50,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will cash the check or money order as if these restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular account statement. You will not receive your original check back. The bank will destroy your

original check, but will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed account, the bank will attempt to make the transfer up to 2 times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

Interest: Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

Delinquent Charges: A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

Administrative Costs: Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.



Paula Dixon-Roderick
Area Director

11/17/2014
Date