

U.S. Department of Labor
Occupational Safety and Health Administration
Suite 375
1033 La Posada Dr.
Austin, TX 78752
Phone: (512)374-0271 FAX: (512)374-0086

COPY



Citation and Notification of Penalty

To:
JM CONSTRUCTION
and its successors
1805 S. CARRIER PKWY.
GRAND PRAIRIE, TX 75051

Inspection Number: 315625632
Inspection Date(s): 06/24/2011-06/24/2011
Issuance Date: 12/19/2011

Inspection Site:
5001 CONVICT HILL RD.
AUSTIN, TX 78749

The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

Please read the following paragraphs which outline your rights and responsibilities.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty you enter into an Informal Settlement Agreement or you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

Posting - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer. **The penalty dollar amounts need not be posted and may be marked out or covered up prior to posting.**

Informal Conference - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period. During such an informal conference you may present any evidence or views which you believe would support an adjustment to the citation(s) and/or penalty(ies).

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of this Citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, call our office between 8:00 a.m. and 4:30 p.m. for an appointment, please **complete, remove and post the page 4 Notice to Employees** next to this Citation and Notification of Penalty as soon as the time, date, and place of the informal conference have been determined. Be sure to bring to the conference any and all supporting documentation of existing conditions as well as any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

Right to Contest - You have the right to contest this Citation and Notification of Penalty. You may contest all citation items or only individual items. You may also contest proposed penalties and/or abatement dates without contesting the underlying violations. Unless you inform the Area Director in writing that you intend to contest the citation(s) and/or proposed penalty(ies) within 15 working days after receipt, the citation(s) and the proposed penalty(ies) will become a final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency.

Penalty Payment - Penalties are due within 15 working days of receipt of this notification unless contested. (See the attached Invoice/Debt Collection Notice for details of the Debt Collection Act of 1982.) Make your check or money order payable to "DOL-OSHA". Please indicate the Inspection Number on the remittance.

OSHA does not agree to any restrictions or conditions or endorsements put on any check or money order for less than the full amount due, and will cash the check or money order as if these restrictions, conditions, or endorsements do not exist.

Notification of Corrective Action - For each violation which you do not contest, you are required by 29 CFR 1903.19 to submit an Abatement Certification to the Area Director of the OSHA office issuing the citation and identified above. The certification must be sent by you within 10 calendar days of the abatement date indicated on the citation. For **Willful** and **Repeat** violations, documents (examples: photos, copies of receipts, training records, etc.) demonstrating that abatement is complete must accompany the certification. Where the citation is classified as **Serious** and the citations states that abatement documentation is required, documents such as those described above are required to be submitted along with the abatement certificate. If the citation indicates that the violation was corrected during the inspection, no abatement certification is required for that item. Attached are two fill-in-the blank form letters for your use to assist you in meeting this requirement.

All abatement verification documents must contain the following information: 1) Your name and address; 2) the inspection number (found on the front page); 3) the citation and citation item number(s) to which the submission relates; 4) a statement that the information is accurate; 5) the signature of the employer or employer's authorized representative; 6) the date the hazard was corrected; 7) a brief statement of how the hazard was corrected; and 8) a statement that affected employees and their representatives have been informed of the abatement.

The law also requires a copy of all abatement verification documents, required by 29 CFR 1903.19 to be sent to OSHA, also be posted at the location where the violation appeared and the corrective action took place.

Employer Discrimination Unlawful - The law prohibits discrimination by an employer against an employee for filing a complaint or for exercising any rights under this Act. An employee who believes that he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the U.S. Department of Labor Area Office at the address shown above.

Notice to Employees - The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must be mailed to the U.S. Department of Labor Area Office at the address shown above and postmarked within 15 working days (excluding weekends and Federal holidays) of the receipt by the employer of this Citation and Notification of Penalty.

Abatement Methods - The employer is not limited to abatement methods suggested by OSHA; i.e., methods explained are general and may not be effective in all cases. Other methods of abatement may be equally or more appropriate. Ultimate responsibility for determining the most appropriate abatement method rests with the employer, given its superior knowledge of the specific conditions at its worksite.

Inspection Activity Data - You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of the Electronic Freedom of Information Act. The information related to your inspection will be available 30 calendar days after the Citation Issuance Date. You are encouraged to review the information concerning your establishment at www.OSHA.gov. If you have any dispute with the accuracy of the information displayed, please contact this office.



NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE

An informal conference has been scheduled with OSHA to discuss the citation(s) issued on 12/19/2011. The conference will be held at the OSHA office located at Suite 375, 1033 La Posada Dr., Austin, TX, 78752 on _____ at _____. Employees and/or representatives of employees have a right to attend an informal conference.

ABATEMENT CERTIFICATION

REFERENCE: JM CONSTRUCTION 315625632
1805 S. CARRIER PKWY.
GRAND PRAIRIE, TX 75051

PLEASE FILL IN ABATEMENT/CORRECTION METHOD INCLUDING DATE COMPLETED FOR EACH ITEM CITED AND RETURN TO THE AREA DIRECTOR. Supporting documentation shall be included; e.g., drawings/photographs, purchase/work orders, air sampling results, or any other related information to show corrections. Abatement verification must be posted and certified as being true and correct. Responses are due **within 10 calendar days** from each abatement date and must be postmarked within the 10 calendar day period.

Citation 1, Item 1: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 2: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 3: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 4: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 5: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 6: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 7: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 8: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 9: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 10: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 11: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 1, Item 12: Serious

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

Citation 2, Item 1: Repeat

DESCRIBE CORRECTIVE ACTION TAKEN & PROVIDE DATE CORRECTED:

JM CONSTRUCTION 315625632
1805 S. CARRIER PKWY.
GRAND PRAIRIE, TX 75051

I attest that the information contained in this document is accurate and that the affected employees and their representatives have been informed of the abatement activities described in this certification.

Certification of Abatement Response by: _____

Title: _____

Date: _____



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 1 Type of Violation: **Serious**

29 CFR 1910.178(l)(4)(iii): An evaluation of each powered industrial truck operator's performance, was not conducted at least once every three years. [Construction Reference 29 CFR 1926.602(d)]

On or about June 20, 2011, an employee of JM Construction was operating the rough terrain, telescoping boom forklift without receiving training from the employer, or an evaluation by a competent person to ensure he was qualified to operate the equipment, exposing the employee to the hazards associated with operating the forklift.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that each powered industrial truck operator has been trained, certified, and evaluated at least every 3 years.

Date By Which Violation Must be Abated: 01/04/2012
Proposed Penalty: \$ 2640.00

See pages 1 through 8 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 2 Type of Violation: **Serious**

29 CFR 1926.20(b)(1): The employer did not initiate and maintain safety and health programs as may be necessary to comply with this part:

(a) On or about June 24, 2011, at the inspection site, exposing employee(s) of JM Construction to conditions which are unsanitary, hazardous, or dangerous to their health or safety.

NOTE: The elements of an effective safety and health program may include, but are not limited to; the following:

- a) Management commitment and leadership
- b) Assignment of Responsibility
- c) Identification and control of hazards
- d) Training and education
- e) Recordkeeping and hazard analysis
- f) First aid, medical training and assistance
- g) Frequent and regular inspections

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that a safety and health program is initiated and maintained.

Date By Which Violation Must be Abated:
Proposed Penalty:

01/04/2012
\$ 3300.00



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 3 Type of Violation: **Serious**

29 CFR 1926.21(b)(2): The employer did not instruct each employee in the recognition and avoidance of unsafe conditions and the regulations applicable to his work environment to control or eliminate any hazards or other exposure to illness or injury.

On or about June 24, 2011, eight employees of JM Construction were performing demolition and framing operations on the east and west sides of building #2 without receiving safety training from the employer, exposing the employees to the hazards associated with their work such as, but not limited to falling from and/or being crushed by falling balconies.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that each employee working for the employer is trained on the hazards associated with their work.

Date By Which Violation Must be Abated: 01/04/2012
Proposed Penalty: \$ 3300.00



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 4 Type of Violation: Serious

29 CFR.451(g)(1)(vii): Each employee on a scaffold, not otherwise specified in paragraphs (g)(1)(i) through (g)(1)(vi) of this section, more than 10 feet (3.1m) above a lower level was not protected from falling to that lower level by the use of personal fall arrest systems or guardrail systems meeting the requirements of paragraph (g)(4) of this section:

On or about June 24, 2011, three employees of JM Construction were utilizing pump jack scaffolding to conduct demolition operations on the east wall of building #2 up to approximately 25 feet high with a guardrail system which was missing a mid rail, or equivalent, on the back of the scaffold platform and no guardrail system on either end of the scaffold platform, exposing the employees to a fall hazard.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that pump jack scaffolding is erected with guardrails to prevent employees from being exposed to fall hazards.

Date By Which Violation Must be Abated: 12/22/2011
Proposed Penalty: \$ 4620.00



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 5 Type of Violation: **Serious**

29 CFR 1926.452(j)(2): Poles were not secured to the structure by rigid triangular bracing or equivalent at the bottom, top, and other points as necessary.

On or about June 24, 2011, three employees of JM Construction were utilizing pump jack scaffolding to conduct demolition operations on the east wall of building #2 up to approximately 25 feet high without having the lower braces to tie the vertical poles into the building, exposing the employees to a fall hazard.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that pump jack scaffolding has poles secured to the structure by rigid triangular bracing at every point necessary.

Date By Which Violation Must be Abated: 12/22/2011
Proposed Penalty: \$ 3300.00

Citation 1 Item 6 Type of Violation: **Serious**

29 CFR 1926.454(a): The employer did not have each employee who performs work while on a scaffold trained by a person qualified in the subject matter to recognize hazards associated with the type of scaffold being used and to understand the procedures to control or minimize those hazards:

On or about June 24, 2011, three employees of JM Construction were utilizing pump jack scaffolding to conduct demolition operations on the east wall of building #2 up to approximately 25 feet high without receiving training from the employer, exposing the employees to fall hazards.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that each employee working on scaffolding receives training on the hazards associated with the type of scaffolding they are using.

Date By Which Violation Must be Abated: 01/04/2012
Proposed Penalty: \$ 4620.00

See pages 1 through 8 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 7 Type of Violation: **Serious**

29 CFR 1926.703(a)(1): Formwork was not designed, fabricated, erected, supported, braced and maintained so that it would be capable of supporting without failure all vertical and lateral loads that could reasonably be anticipated to be applied to the formwork:

On or about June 24, 2011, employees of JM Construction were framing and forming the second and third floor balconies on building #2 up to approximately 16 feet high without sufficient bracing that could support the balconies without failure, exposing the employees to the hazards of falls and others below to the hazards of being struck by falling materials.

On or about June 24, 2011, JM Construction, as the framing contractor and creating employer, did not ensure that employees of the concrete subcontractor, Martin's Concrete Construction, were protected from the hazards of falls and others below to the hazards of being struck by falling materials. Employees of Martin's Concrete Construction were pouring concrete on the tops of the second and third floor balconies on building #2 up to approximately 16 feet high without sufficient bracing that could support the balconies without failure.

On or about June 24, 2011, JM Construction, as the framing contractor and creating employer, did not ensure that employees of the general contractor, Stir Construction were protected from the hazards of falls and others below to the hazards of being struck by falling materials. An employee of Stir Construction was on the second and third floor balconies of building #2 up to approximately 16 feet high without sufficient bracing that could support the balconies without failure.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that all formwork is designed, fabricated, erected, supported, braced and maintained so that it is capable of supporting without failure all vertical and lateral loads that could reasonably be anticipated to be applied to the formwork.

Date By Which Violation Must be Abated: 12/22/2011
Proposed Penalty: \$ 4620.00

See pages 1 through 8 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 8 Type of Violation: **Serious**

29 CFR 1926.703(a)(2): Drawings or plans, including all revisions, for the jack layout, formwork (including shoring equipment), working decks, and scaffolds were not available at the jobsite:

On or about June 24, 2011, employees of JM Construction were accessing and working from the second and third floor balconies of Building #2 up to approximately 16 feet high that were supported with 2X6, single-post shoring without the drawings or plans that included the shoring being on site, exposing workers to the hazards of falls and others below to the hazards of being struck by falling materials.

On or about June 24, 2011, JM Construction, as the framing contractor and creating employer, did not ensure that drawings or plans that included the single-post shoring were available on the site where employees of Martin's Concrete Construction were accessing and working from the second and third floor balconies of Building #2 up to approximately 16 feet high, exposing the employees to a fall hazard.

On or about June 24, 2011, JM Construction, as the framing contractor and creating employer, did not ensure that drawings or plans that included the single-post shoring were available on the site where an employee of the general contractor, Stir Construction accessed and worked from the second and third floor balconies of Building #2 up to approximately 16 feet high, exposing the employee to a fall hazard.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that all drawings or plans, including all revisions for formwork are available on the job site.

Date By Which Violation Must be Abated: 12/22/2011
Proposed Penalty: \$ 4620.00



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 9 Type of Violation: **Serious**

29 CFR 1926.703(b)(3): Erected shoring equipment was not inspected immediately prior to, during, and immediately after concrete placement:

On or about June 24, 2011, employees of JM Construction were working around and below the second and third floor balconies of Building #2 that were being poured with concrete without the shoring supporting the balconies being inspected before and during the pour, exposing the employees to the hazard of being struck by falling materials.

On or about June 24, 2011, JM Construction, as the framing contractor and creating employer, did not ensure that the second and third floor balcony shoring was inspected before and during the concrete pours on Building #2 where employees of Martin's Concrete Construction were accessing and working from them up to approximately 16 feet high, exposing the employees to a fall hazard.

On or about June 24, 2011, JM Construction, as the framing contractor and creating employer, did not ensure that the shoring that was supporting the second and third floor balconies was inspected during the concrete pours on Building #2 where an employee of the general contractor, Stir Construction, accessed and worked below, exposing the employee to the hazard of being struck by falling materials.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that erected shoring equipment is inspected before, during and after concrete pouring operations.

Date By Which Violation Must be Abated: 12/22/2011
Proposed Penalty: \$ 4620.00



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 10 Type of Violation: **Serious**

29 CFR 1926.703(b)(7): Shore heads and similar members were subjected to eccentric loading for which they had not been designed:

On or about June 24, 2011, employees of JM Construction were accessing and working from the second and third floor balconies of Building #2 up to approximately 16 feet high with shoring that was subjected to eccentric loading for which it was not designed, exposing the employees to the hazards of falls and others below to the hazard of being struck by falling materials.

On or about June 24, 2011, JM Construction, as the framing contractor and creating employer, did not ensure that the shoring supporting the second and third floor balconies on Building #2 were not subjected to eccentric loading where employees of Martin's Concrete Construction were pouring concrete, exposing the employees to a fall hazard.

On or about June 24, 2011, JM Construction, as the framing contractor and creating employer, did not ensure that the shoring supporting the second and third floor balconies on Building #2 were not subjected to eccentric loading where an employee of the general contractor, Stir Construction, accessed and worked from the second and third floor balconies of Building #2 up to approximately 16 feet high, exposing the employee to a fall hazard and others below to the hazard of being struck by falling materials.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that shore heads and similar shoring members are not subjected to eccentric loading.

Date By Which Violation Must be Abated:

12/22/2011

Proposed Penalty:

\$ 4620.00

See pages 1 through 8 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 11 Type of Violation: **Serious**

29 CFR 1926.703(b)(8)(i): The design of the tiered (single post shores used on top of one another) post shore system was not prepared by a qualified designer and/or the erected shoring was not inspected by an engineer qualified in structural design:

On or about June 24, 2011, employees of JM Construction were accessing and working from the second and third floor balconies of Building #2 up to approximately 16 feet high that were supported with shoring that was not designed or inspected by a qualified designer, exposing the employees to a fall hazard and others below to the hazard of being struck by falling materials.

On or about June 24, 2011, JM Construction, as the framing contractor and creating employer, did not ensure that the shoring supporting the second and third floor balconies on Building #2 was designed and inspected by a qualified designer where employees of Martin's Concrete Construction were pouring concrete, exposing the employees to a fall hazard.

On or about June 24, 2011, JM Construction, as the framing contractor and creating employer, did not ensure that the shoring supporting the second and third floor balconies on Building #2 was designed and inspected by a qualified designer where an employee of the general contractor, Stir Construction, accessed and worked from the second and third floor balconies of Building #2 up to approximately 16 feet high, exposing the employee to a fall hazard and others below to the hazard of being struck by falling materials.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that tiered shoring systems are prepared by a qualified designer and/or the erected shoring is inspected by an engineer qualified in structural design.

Date By Which Violation Must be Abated: 12/22/2011
Proposed Penalty: \$ 4620.00



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 1 Item 12 Type of Violation: **Serious**

29 CFR 1926.1060(a): The employer did not provide a training program for each employee using ladders and stairways which would train each employee in the procedures to be followed to minimize hazards related to ladders and stairways:

On or about June 24, 2011, eight employees of JM Construction were utilizing multiple 20 foot aluminum extension ladders to access the second and third floor balconies up to approximately 16 feet high on Building #2 without receiving ladder training from the employer, exposing the employees to the hazards of falls.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that each employee using ladders is trained in the procedures to be followed to minimize hazards related to ladders and stairways.

Date By Which Violation Must be Abated: 01/04/2012
Proposed Penalty: \$ 3300.00



Citation and Notification of Penalty

Company Name: JM CONSTRUCTION
Inspection Site: 5001 CONVICT HILL RD., AUSTIN, TX 78749

Citation 2 Item 1 Type of Violation: **Repeat**

29 CFR 1926.501(b)(13): Employee(s) engaged in residential construction 6 feet (1.8 m) or more above lower levels were not protected from falling by the use of guardrail systems, safety net systems or personal fall arrest systems nor was an alternative fall protection plan which meets the requirements of 1926.502(k) developed and implemented :


On or about June 24, 2011, employees of JM Construction were framing and forming the second and third floor balconies of the apartment complex being remodeled up to approximately 16 feet high without fall protection, exposing the employees to a fall hazard.

JM Construction was previously cited for a violation of this Occupational Safety and Health Standard or its equivalent standard 29 CFR 1926.501(b)(13), which was contained in Inspection Number: 309544542, Citation Number: 02, Item: 01, issued on: July 10, 2007, and was affirmed as a Final Order on August 21, 2007, with respect to a workplace located at: 241 East Interstate 30 Garland, Texas 75043.

JM Construction was previously cited for a violation of this Occupational Safety and Health Standard or its equivalent standard 29 CFR 1926.501(b)(13), which was contained in Inspection Number: 308635721, Citation Number: 01, Item: 01, issued on: March 16, 2005, and was affirmed as a Final Order on May 9, 2005, with respect to a workplace located at: 2150 Meridian, Wichita, Kansas 67212.

Pursuant to 29 C.F.R. 1903.19, within ten (10) calendar days of the date of this citation, the employer must submit documentation showing that it is in compliance with the standard, including describing the steps that it is taking to ensure that each employee working in an elevated position 6 feet or more above lower levels is provided fall protection.

Date By Which Violation Must be Abated: 12/22/2011
Proposed Penalty: \$ 23100.00


R. Casey Perkins, CSP
Area Director

See pages 1 through 8 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities..

