



Citation and Notification of Penalty

Company Name: Jasper Contractors, Inc.
Inspection Site: 12357 Boston Harbor Drive, Jacksonville, FL 32225

Citation 1 Item 1 Type of Violation: **Willful**

29 CFR 1926.102(a)(1): Eye and face protective equipment are not used when machines or operations present potential eye or face injury from physical, chemical, or radiation agents:

a. The employer fails to assure effective protection against eye and face injuries as required by the standard, as demonstrated on March 4, 2015, when employees are working on a residential roof at 12357 Boston Harbor Drive, Jacksonville Florida 32225 without eye protection while using pneumatic nail guns and were exposed to eye injuries from flying debris or nails. Jasper Contractors, Inc., previously committed a serious violation of this standard on September 11, 2012, with respect to a workplace at 2927 Newbury Court, Highlands Ranch, CO, which became a final order on November 28, 2012 (Inspection No. 626158).

Jasper Contractors, Inc., previously committed a serious violation of this standard on July 25, 2012, with respect to a workplace at, 10775 Glengate Loop, Littleton, CO, which became a final order on November 28, 2012 (Inspection No. 546338).

To abate this violation, the employer must ensure that all employees wear appropriate eye protection when an employee is using a pneumatic air gun.

Pursuant to 29 CFR 1903.19, the employer must submit documents describing the steps it is taking to ensure compliance, including an explanation of how these steps protect its employees from eye injuries.

Date By Which Violation Must be Abated: _____ Corrected During Inspection
Proposed Penalty: \$70000.00



Citation and Notification of Penalty

Company Name: Jasper Contractors, Inc.

Inspection Site: 12357 Boston Harbor Drive, Jacksonville, FL 32225

Citation 1 Item 2 Type of Violation: **Willful**

29 CFR 1926.501(b)(13): Each employee(s) engaged in residential construction activities 6 feet (1.8 m) or more above lower levels are not protected by guardrail systems, safety net system, or personal fall arrest system, nor are employee(s) provided with an alternative fall protection measure under another provision of paragraph 1926.501(b):

a. The employer fails to assure effective protection against falls as required by the standard, as demonstrated on March 4, 2015, when employees are working on a residential roof at 12357 Boston Harbor Drive, Jacksonville Florida 32225 without fall protection and were exposed to falls of approximately 13 feet.

Jasper Contractors, Inc., previously committed a serious violation of this standard on March 25, 2014, with respect to a workplace at 12983 Bent Water, Jacksonville, FL 32215, which became a final order on July 31, 2014, (Inspection No. 964742).

Jasper Contractors, Inc., previously committed a willful violation of this standard on May 12, 2014, with respect to a workplace at 355 Silent Brook Trail, Jacksonville, Florida 32225, which was contested (Inspection No. 976501).

Jasper Contractors, Inc., previously committed a serious violation of this standard on August 28, 2014, with respect to a workplace at 11760 Heather Grove Lane, Jacksonville, Florida 32223, which was contested (Inspection No. 992409).

Jasper Contractors, Inc., previously committed a serious violation of this standard on July 25, 2012, with respect to a workplace at, 10775 Glengate Loop, Littleton, CO, which became a final order on November 28, 2012 (Inspection No. 546338).

Jasper Contractors, Inc., previously committed a serious violation of this standard on September 11, 2012, with respect to a workplace at 2927 Newbury Court, Highlands Ranch, CO, which became a final order on November 28, 2012 (Inspection No. 626158).

Jasper Contractors, Inc., previously committed a serious violation of this standard on April 21, 2011,

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1044055
Inspection Date(s): 03/04/2015 - 03/27/2015
Issuance Date: 07/10/2015



Citation and Notification of Penalty

Company Name: Jasper Contractors, Inc.
Inspection Site: 12357 Boston Harbor Drive, Jacksonville, FL 32225

with respect to a workplace at 3236 Robert Circle, Gretna, LA, which became a final order on May 24, 2011 (Inspection No. 314770249).

Jasper Contractors, Inc., previously committed a serious violation of this standard on September 24, 2010, with respect to a workplace at 713 Valley View Road, Woodland Park, CO which became a final order on February 24, 2011 (Inspection No. 313722787).

Jasper Contractors, Inc., previously committed a repeat violation of this or an equivalent standard on August 27, 2009, with respect to a workplace at 4411 Saratoga Woods Drive, Louisville, KY, which became a final order on November 2, 2009 (Inspection No. 313188492).

To abate this violation, the employer must ensure that all employees wear appropriate fall protection or install a guardrail or safety net system when an employee works 6 feet or more above lower levels.

Pursuant to 29 CFR 1903.19, the employer must submit documents describing the steps it is taking to ensure compliance, including an explanation of how these steps protect its employees from fall hazards.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated: 08/05/2015
Proposed Penalty: \$70000.00

A handwritten signature in black ink, appearing to read "Brian J. Sturtecky", written over a horizontal line.

Brian J. Sturtecky
Area Director

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.