

U.S. Department of Labor
Occupational Safety and Health Administration
1099 Winterson Road
Suite 140
Linthicum, MD 21090
Phone: 410-865-2055 Fax: 410-865-2068



Citation and Notification of Penalty

To:
Oscar Cruz Construction, dba Master Carpentry, Inc.
and its successors
7716 Lake Dr.
Manassas, VA 20111

Inspection Number: 1214330
Inspection Date(s): 02/27/2017 - 02/27/2017
Issuance Date: 04/05/2017

Inspection Site:
1609 Lewis St., NE
Washington, DC 20002

The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty you either call to schedule an informal conference (see paragraph below) or you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Please refer to the enclosed booklet (OSHA 3000) which outlines your rights and responsibilities and which should be read in conjunction with this form. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

Posting - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer.

Informal Conference - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period. During such an informal conference you may present any evidence or views which you believe would support an adjustment to the citation(s) and/or penalty(ies).

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of this Citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete, remove and post the Notice to Employees next to this Citation and Notification of Penalty as soon as the time, date, and place of the informal conference have been determined. Be sure to bring to the conference any and all supporting documentation of existing conditions as well as any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

Right to Contest – You have the right to contest this Citation and Notification of Penalty. You may contest all citation items or only individual items. You may also contest proposed penalties and/or abatement dates without contesting the underlying violations. Unless you inform the Area Director in writing that you intend to contest the citation(s) and/or proposed penalty(ies) within 15 working days after receipt, the citation(s) and the proposed penalty(ies) will become a final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency.

Penalty Payment – Penalties are due within 15 working days of receipt of this notification unless contested. (See the enclosed booklet and the additional information provided related to the Debt Collection Act of 1982.) Make your check or money order payable to “DOL-OSHA”. Please indicate the Inspection Number on the remittance. You can also make your payment electronically on www.pay.gov. On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type "OSHA" and click Go. From the results, click on OSHA Penalty Payment Form. The direct link is:

<https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>.

You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will process the payments as if these restrictions or conditions do not exist.

Notification of Corrective Action – For each violation which you do not contest, you must provide *abatement certification* to the Area Director of the OSHA office issuing the citation and identified above. This abatement certification is to be provided by letter within 10 calendar days after each abatement date. Abatement certification includes the date and method of abatement. If the citation indicates that the violation was corrected during the inspection, no abatement certification is required for that item. The abatement certification letter must be posted at the location where the violation appeared and the corrective action took place or employees must otherwise be effectively informed about abatement activities. A sample abatement certification letter is enclosed with this Citation. In addition, where the citation indicates that *abatement documentation* is necessary, evidence of the purchase or repair of equipment, photographs or video, receipts, training records, etc., verifying that abatement has occurred is required to be provided to the Area Director.

Employer Discrimination Unlawful – The law prohibits discrimination by an employer against an

employee for filing a complaint or for exercising any rights under this Act. An employee who believes that he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the U.S. Department of Labor Area Office at the address shown above.

Employer Rights and Responsibilities – The enclosed booklet (OSHA 3000) outlines additional employer rights and responsibilities and should be read in conjunction with this notification.

Notice to Employees – The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must be mailed to the U.S. Department of Labor Area Office at the address shown above and postmarked within 15 working days (excluding weekends and Federal holidays) of the receipt by the employer of this Citation and Notification of Penalty.

Inspection Activity Data – You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of the Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at www.osha.gov. If you have any dispute with the accuracy of the information displayed, please contact this office.



NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE

An informal conference has been scheduled with OSHA to discuss the citation(s) issued on 04/05/2017. The conference will be held by telephone or at the OSHA office located at 1099 Winterson Road, Suite 140, Linthicum, MD 21090 on _____ at

_____. Employees and/or representatives of employees have a right to attend an informal conference.

CERTIFICATION OF CORRECTIVE ACTION WORKSHEET

Inspection Number: 1214330

Company Name: Oscar Cruz Construction, dba Master Carpentry, Inc.
Inspection Site: 1609 Lewis St., NE, Washington, DC 20002
Issuance Date: 04/05/2017

List the specific method of correction for each item on this citation in this package that does not read "Corrected During Inspection" and return to: **U.S. Department of Labor – Occupational Safety and Health Administration, 1099 Winterson Road, Suite 140, Linthicum, MD 21090**

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

I certify that the information contained in this document is accurate and that the affected employees and their representatives have been informed of the abatement.

Signature

Date

Typed or Printed Name

Title

NOTE: 29 USC 666(g) whoever knowingly makes any false statements, representation or certification in any application, record, plan or other documents filed or required to be maintained pursuant to the Act shall, upon conviction, be punished by a fine of not more than \$10,000 or by imprisonment of not more than 6 months or both.

POSTING: A copy of completed Corrective Action Worksheet should be posted for employee review

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1214330
Inspection Date(s): 02/27/2017 - 02/27/2017
Issuance Date: 04/05/2017



Citation and Notification of Penalty

Company Name: Oscar Cruz Construction, dba Master Carpentry, Inc.
Inspection Site: 1609 Lewis St., NE, Washington, DC 20002

Citation 1 Item 1 Type of Violation: **Serious**

29 CFR 1926.150(c)(1)(vi): A fire extinguisher, rated not less than 10B, was not provided within 50 feet of wherever more than 5 gallons of flammable or combustible liquids or 5 pounds of flammable gas were being used on the jobsite:

a) Roof - On or about February 27, 2017, a worker who had not been provided with a portable fire extinguisher was exposed to a fire hazard while operating a torch fueled by a 20 lbs. LP gas cylinder.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the Certification of Corrective Action Worksheet).

Date By Which Violation Must be Abated:
Proposed Penalty:

04/11/2017
\$2390.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 1214330
Inspection Date(s): 02/27/2017 - 02/27/2017
Issuance Date: 04/05/2017



Citation and Notification of Penalty

Company Name: Oscar Cruz Construction, dba Master Carpentry, Inc.
Inspection Site: 1609 Lewis St., NE, Washington, DC 20002

Citation 1 Item 2 Type of Violation: **Serious**

29 CFR 1926.1053(b)(1): Where (a) portable ladder(s) was/were used for access to an upper level landing surface and the ladder's length did not allow the ladder side rails to extend at least 3 feet (0.9 m) above the upper landing surface being accessed, the ladder was not secured at its top to a rigid support that will not deflect, and/or a grasping device was not provided to assist employees in mounting and dismounting the ladder:

a) Third Floor - On or about February 27, 2017, a worker was exposed to a 10 foot fall from a wooden job-made ladder whose top was located 1 foot below the roof or ladder landing.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the Certification of Corrective Action Worksheet).

Date By Which Violation Must be Abated:
Proposed Penalty:

04/11/2017
\$2390.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Oscar Cruz Construction, dba Master Carpentry, Inc.
Inspection Site: 1609 Lewis St., NE, Washington, DC 20002

Citation 2 Item 1 Type of Violation: **Repeat**

29 CFR 1926.501(b)(13): Each employee engaged in residential construction activities 6 feet (1.8 m) or more above lower levels were not protected by guardrail systems, safety net system, or personal fall arrest system unless another provision in paragraph (b) of this section provides for an alternative fall protection measure:

- a) Roof - On or about February 27, 2017, a worker installing capping on the parapet of a flat roof was not provided with fall protection while exposed to a 35 ft. fall.
- b) Roof - On or about February 27, 2017, a worker installing capping on the parapet of a flat roof was exposed to a 10 ft. fall through a 2 foot by 4 foot skylight opening which was not provide with a cover.
- c) Roof - On or about February 27, 2017, a worker installing capping on the parapet of a flat roof was exposed to a 10 ft. fall through a 2 foot by 2 foot opening or floor hole which was not covered.
- d) Third Floor - On or about February 27, 2017, a worker was exposed to a 7 foot fall while walking near to an open-sided floor next to a stairway where no fall protection was provided.

Oscar Cruz Construction dba Master Carpentry, Inc. was previously cited for a violation of this occupational safety and health standard 29 CFR 1926.501(b)(13), which was contained in OSHA inspection number 1123662, citation number 1, item number 1 and was affirmed as a final order on 05/19/2016, with respect to a workplace located at 1048 48th. Pl., NE, Washington, DC 20019.

Oscar Cruz Construction was previously cited for a violation of this occupational safety and health standard 29 CFR 1926.501(b)(13), which was contained in OSHA inspection number 1001984, citation number 1, item number 2 and was affirmed as a final order on 02/04/2015, with respect to a workplace located at 2841 Belair Rd., NE, Washington, DC 20007.

Oscar Cruz Construction was previously cited for a violation of this occupational safety and health standard 29 CFR 1926.501(b)(13), which was contained in OSHA inspection number 1042573, citation number 1, item number 1 and was affirmed as a final order on 04/17/2015, with respect to a workplace

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Oscar Cruz Construction, dba Master Carpentry, Inc.
Inspection Site: 1609 Lewis St., NE, Washington, DC 20002

located at 911 12th. St., NE, Washington, DC 20002.

Oscar Cruz Construction was previously cited for a violation of this occupational safety and health standard 29 CFR 1926.501(b)(13), which was contained in OSHA inspection number 1071280, citation number 2, item number 1 and was affirmed as a final order on 12/15/2015, with respect to a workplace located at 816 Kennedy St., NW, Washington, DC 20011.

Oscar Cruz Construction was previously cited for a violation of this occupational safety and health standard 29 CFR 1926.501(b)(13), which was contained in OSHA inspection number 1073461, citation number 1, item number 1 and was affirmed as a final order on 10/13/2015, with respect to a workplace located at 422 58th. St., NE, Washington, DC 20019.

Oscar Cruz Construction was previously cited for a violation of this occupational safety and health standard 29 CFR 1926.501(b)(13), which was contained in OSHA inspection number 1018431, citation number 2, item number 2 and was affirmed as a final order on 04/16/2015, with respect to a workplace located at 411 Ridge St., Washington, DC 20001.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the Certification of Corrective Action Worksheet), in addition, documentation demonstrating the abatement is complete must be included with your certification. This documentation may include, but is not limited to evidence of the purchase or repair of the equipment, photographic or video evidence of abatement, or other written records.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:
Proposed Penalty:

04/11/2017
\$41828.00



Citation and Notification of Penalty

Company Name: Oscar Cruz Construction, dba Master Carpentry, Inc.
Inspection Site: 1609 Lewis St., NE, Washington, DC 20002

Citation 2 Item 2 Type of Violation: **Repeat**

29 CFR 1926.1052(c)(1)(i): Stairways having four or more risers or rising more than 30 inches (76 cm), whichever is less, were not equipped with at least one handrail:

- a) Stairway, First to Second Floor - On or about February 27, 2017, a worker was exposed to up to a 10 foot fall down a set of stairs having six risers which had not been provided with a hand rail.
- b) Stairway, Second to Third Floor - On or about February 27, 2017, a worker was exposed to up to a 10 foot fall down a set of stairs having six risers which had not been provided with a hand rail.

Oscar Cruz was previously cited for a violation of this occupational safety and health standard 29 CFR 1926.1052(c)(1)(i), which was contained in OSHA inspection number 1047143, citation number 1, item number 2a and was affirmed as a final order on 09/04/2015, with respect to a workplace located at 746 19th Street, NE, Washington, DC 20002.

In accordance with 29 CFR 1903.19(d), abatement certification is required for this violation (using the Certification of Corrective Action Worksheet), in addition, documentation demonstrating the abatement is complete must be included with your certification. This documentation may include, but is not limited to evidence of the purchase or repair of the equipment, photographic or video evidence of abatement, or other written records.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:
Proposed Penalty:

04/11/2017
\$4780.00


Nadira Janack
Area Director

U.S. Department of Labor
Occupational Safety and Health Administration
1099 Winterson Road
Suite 140
Linthicum, MD 21090
Phone: 410-865-2055 Fax: 410-865-2068



INVOICE / DEBT COLLECTION NOTICE

Company Name: Oscar Cruz Construction, dba Master Carpentry, Inc.
Inspection Site: 1609 Lewis St., NE, Washington, DC 20002
Issuance Date: 04/05/2017

Summary of Penalties for Inspection Number	1214330
Citation 1, Serious	\$4780.00
Citation 2, Repeat	\$46608.00
TOTAL PROPOSED PENALTIES	\$51388.00

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance. You can also make your payment electronically on www.pay.gov. On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type "OSHA" and click Go. From the results, click on **OSHA Penalty Payment Form**. The direct link is <https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>. You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$25,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will cash the check or money order as if these restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular account statement. You will not receive your original check back. The bank will destroy your original check, but will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed


account, the bank will attempt to make the transfer up to 2 times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

Interest: Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

Delinquent Charges: A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

Administrative Costs: Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.



Nadira Janack
Area Director



Date