



Citation and Notification of Penalty

Company Name: Great White Construction, Inc.
Inspection Site: 4324 Queensway Dr, Jacksonville, FL 32257

Citation 1 Item 1 Type of Violation: **Willful**

29 CFR 1926.501(b)(13): Each employee(s) engaged in residential construction activities 6 feet (1.8 m) or more above lower levels were not protected by guardrail systems, safety net system, or personal fall arrest system, nor were employee(s) provided with an alternative fall protection measure under another provision of paragraph 1926.501 (b):

a. Employees performing roofing work on a 6/12-pitch roof 6 feet or more above ground are not protected from 8ft-3in and 12ft-10in fall hazards by a fall protection system. This violation was most recently observed on or about September 25, 2014, at a job site located at 4324 Queensway Dr., Jacksonville, Florida.

Great White Construction, Inc. was previously cited for a violation of this occupational safety and health standard, which was contained in OSHA inspection number 447093, Other-than-serious citation number 1, item number 2 and was affirmed as a final order on June 27, 2012, with respect to a workplace located at 12957 Everett St, Jacksonville, Florida.

Great White Construction, Inc. was previously cited for a violation of this occupational safety and health standard, which was contained in OSHA inspection number 931265, Repeat Serious citation number 1, item number 2 and was affirmed as a final order on November 6, 2013, with respect to a workplace located at 2276 Gabriel Drive, Orange Park, Florida.

Great White Construction, Inc. was previously cited for a violation of this occupational safety and health standard, which was contained in OSHA inspection number 941605, Repeat Serious citation number 1, item number 1 and was affirmed as a final order on November 6, 2013, with respect to a workplace located at 1421 Chablis Court North, Orange Park, Florida.

Great White Construction, Inc. was previously cited for a violation of this occupational safety and health standard, which was contained in OSHA inspection number 959679, Repeat Serious citation number 1, item number 1 and was affirmed as a final order on April 23, 2014, with respect to a workplace located at 96 Bayside Dr., Palm Coast, Florida.

To abate this violation, the employer must ensure that all employees working at elevations of 6 feet or

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 996902
Inspection Date(s): 09/25/2014 - 09/25/2014
Issuance Date: 03/20/2015



Citation and Notification of Penalty

Company Name: Great White Construction, Inc.
Inspection Site: 4324 Queensway Dr, Jacksonville, FL 32257

greater are protected from falls by a fall protection system. Pursuant to 29 CFR 1903.19, the employer must submit documents describing the steps it is taking to ensure compliance; including and explanation of how these steps protect its employees from fall hazards.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated: 04/15/2015
Proposed Penalty: \$70000.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Great White Construction, Inc.
Inspection Site: 4324 Queensway Dr, Jacksonville, FL 32257

Citation 2 Item 1 Type of Violation: **Repeat**

29 CFR 1926.102(a)(1): Eye and face protective equipment were not used when machines or operations presented potential eye or face injury from physical, chemical, or radiation agents:

- a. On or about September 25, 2014, at the north side of the building, employees using pneumatic air nail guns to install shingles on a roof were not wearing eye protection, exposing themselves to being struck by flying debris or nails.
- b. On or about September 25, 2014, at the northwest side of the building, an employee using a Black and Decker circular saw to cut plywood on the ground was not wearing eye protection, exposing himself to being struck by flying debris.

Great White Construction, Inc. was previously cited for a violation of this occupational safety and health standard, which was contained in OSHA inspection number 447093, Serious citation number 1, item number 1 and was affirmed as a final order on June 27, 2012, with respect to a workplace located at 12957 Everett St, Jacksonville, Florida.

Great White Construction, Inc. was previously cited for a violation of this occupational safety and health standard, which was contained in OSHA inspection number 931265, Repeat Serious citation number 1, item number 1 and was affirmed as a final order on November 6, 2013, with respect to a workplace located at 2276 Gabriel Drive, Orange Park, Florida.

Date By Which Violation Must be Abated:
Proposed Penalty:

Corrected During Inspection
\$22000.00

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 996902
Inspection Date(s): 09/25/2014 - 09/25/2014
Issuance Date: 03/20/2015



Citation and Notification of Penalty

Company Name: Great White Construction, Inc.
Inspection Site: 4324 Queensway Dr, Jacksonville, FL 32257

Citation 3 Item 1 Type of Violation: **Other-than-Serious**

29 CFR 1926.405(g)(2)(iv): Flexible cords were not connected to devices and fittings so that strain relief is provided to prevent pull from being directly transmitted to joints or terminal screws:

- a. On or about September 25, 2014, at the north west side of the building, the extension cord being used for the Black and Decker circular saw had the strain relief broken with exposed internal wiring.

Date By Which Violation Must be Abated:
Proposed Penalty:

Corrected During Inspection
\$0.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 996902
Inspection Date(s): 09/25/2014 - 09/25/2014
Issuance Date: 03/20/2015



Citation and Notification of Penalty

Company Name: Great White Construction, Inc.
Inspection Site: 4324 Queensway Dr, Jacksonville, FL 32257

Citation 3 Item 2 Type of Violation: **Other-than-Serious**

29 CFR 1926.503(a)(1): The employer did not provide a training program for each employee potentially exposed to fall hazards to enable each employee to recognize the hazards of falling and the procedures to be followed in order to minimize these hazards:

- a. On or about September 25, 2014, at the north side of the building, employees performing roof work on a steep-pitch roof 6 feet or more above ground were not properly trained in the use of personal fall arrest systems and were exposed to body injuries.

ABATEMENT DOCUMENTATION REQUIRED FOR THIS ITEM

Date By Which Violation Must be Abated:
Proposed Penalty:

04/15/2015
\$0.00

A handwritten signature in black ink, appearing to read "Brian J. Sturtecky". The signature is written over a horizontal line.

Brian J. Sturtecky
Area Director

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration
1851 Executive Center Drive
Suite 227
Jacksonville, FL 32207
Phone: 904-232-2895 Fax: 904-232-1294



INVOICE / DEBT COLLECTION NOTICE

Company Name: Great White Construction, Inc.
Inspection Site: 4324 Queensway Dr, Jacksonville, FL 32257
Issuance Date: 03/20/2015

Summary of Penalties for Inspection Number	996902
Citation 1, Willful	\$70000.00
Citation 2, Repeat	\$22000.00
Citation 3, Other-than-Serious	\$0.00
TOTAL PROPOSED PENALTIES	\$92000.00

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance. You can also make your payment electronically on www.pay.gov. On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type "OSHA" and click Go. From the results, click on **OSHA Penalty Payment Form**. The direct link is <https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>. You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$50,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will cash the check or money order as if these restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular account statement. You will not receive your original check back. The bank will destroy your

original check, but will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed account, the bank will attempt to make the transfer up to 2 times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.

Interest: Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.


Delinquent Charges: A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

Administrative Costs: Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.



Brian J. Sturtecky

Area Director



Date