

U.S. Department of Labor
Occupational Safety and Health Administration
365 Smoke Tree Plaza
North Aurora, IL 60542
Phone: 630-896-8700 Fax: 630-892-2160



Citation and Notification of Penalty

To:
Bosco Custom Homes, Inc.
and its successors
P.O. Box 211
Batavia, IL 60510

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014

Inspection Site:
226 E. Parkway Dr.
Wheaton, IL 60187

The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty **you either call to schedule an informal conference (see paragraph below) or** you mail a notice of contest to the U.S. Department of Labor Area Office at the address shown above. Please refer to the enclosed booklet (OSHA 3000) which outlines your rights and responsibilities and which should be read in conjunction with this form. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

Posting - The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer.

Informal Conference - An informal conference is not required. However, if you wish to have such a conference you may request one with the Area Director during the 15 working day contest period. During such an informal conference you may present any evidence or views which you believe would support an adjustment to the citation(s) and/or penalty(ies).

If you are considering a request for an informal conference to discuss any issues related to this Citation and Notification of Penalty, you must take care to schedule it early enough to allow time to contest after the informal conference, should you decide to do so. Please keep in mind that a written letter of intent to contest must be submitted to the Area Director within 15 working days of your receipt of this Citation. The running of this contest period is not interrupted by an informal conference.

If you decide to request an informal conference, please complete, remove and post the Notice to Employees next to this Citation and Notification of Penalty as soon as the time, date, and place of the informal conference have been determined. Be sure to bring to the conference any and all supporting documentation of existing conditions as well as any abatement steps taken thus far. If conditions warrant, we can enter into an informal settlement agreement which amicably resolves this matter without litigation or contest.

Right to Contest – You have the right to contest this Citation and Notification of Penalty. You may contest all citation items or only individual items. You may also contest proposed penalties and/or abatement dates without contesting the underlying violations. **Unless you inform the Area Director in writing that you intend to contest the citation(s) and/or proposed penalty(ies) within 15 working days after receipt, the citation(s) and the proposed penalty(ies) will become a final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency.**

Penalty Payment – Penalties are due within 15 working days of receipt of this notification unless contested. (See the enclosed booklet and the additional information provided related to the Debt Collection Act of 1982.) Make your check or money order payable to “DOL-OSHA”. Please indicate the Inspection Number on the remittance. You can also make your payment electronically on www.pay.gov. On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type “OSHA” and click Go. From the results, click on **OSHA Penalty Payment Form**. The direct link is:

<https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>.

You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$50,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will process the payments as if these restrictions or conditions do not exist.

Notification of Corrective Action – For each violation which you do not contest, you must provide **abatement certification** to the Area Director of the OSHA office issuing the citation and identified above. This abatement certification is to be provided by letter within 10 calendar days after each abatement date. Abatement certification includes the date and method of abatement. If the citation indicates that the violation was corrected during the inspection, no abatement certification is required for that item. The abatement certification letter must be posted at the location where the violation appeared and the corrective action took place or employees must otherwise be effectively informed about abatement activities. A sample abatement certification letter is enclosed with this Citation. In addition, where the citation indicates that **abatement documentation** is necessary, evidence of the purchase or repair of equipment, photographs or video, receipts, training records, etc., verifying that abatement has occurred is required to be provided to the Area Director.

Employer Discrimination Unlawful – The law prohibits discrimination by an employer against an

employee for filing a complaint or for exercising any rights under this Act. An employee who believes that he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the U.S. Department of Labor Area Office at the address shown above.

Employer Rights and Responsibilities – The enclosed booklet (OSHA 3000) outlines additional employer rights and responsibilities and should be read in conjunction with this notification.

Notice to Employees – The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must be mailed to the U.S. Department of Labor Area Office at the address shown above and postmarked within 15 working days (excluding weekends and Federal holidays) of the receipt by the employer of this Citation and Notification of Penalty.

Inspection Activity Data – You should be aware that OSHA publishes information on its inspection and citation activity on the Internet under the provisions of the Electronic Freedom of Information Act. The information related to these alleged violations will be posted when our system indicates that you have received this citation. You are encouraged to review the information concerning your establishment at www.osha.gov. If you have any dispute with the accuracy of the information displayed, please contact this office.



NOTICE TO EMPLOYEES OF INFORMAL CONFERENCE

An informal conference has been scheduled with OSHA to discuss the citation(s) issued on 10/28/2014. The conference will be held by telephone or at the OSHA office located at 365 Smoke Tree Plaza, North Aurora, IL 60542 on _____ at _____.

Employees and/or representatives of employees have a right to attend an informal conference.

CERTIFICATION OF CORRECTIVE ACTION WORKSHEET

Inspection Number: 980163

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187
Issuance Date: 10/28/2014

List the specific method of correction for each item on this citation in this package that does not read "Corrected During Inspection" and return to: **U.S. Department of Labor – Occupational Safety and Health Administration, 365 Smoke Tree Plaza, North Aurora, IL 60542**

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

Citation Number _____ and Item Number _____ was corrected on _____
By (Method of Abatement): _____

I certify that the information contained in this document is accurate and that the affected employees and their representatives have been informed of the abatement.

Signature

Date

Typed or Printed Name

Title

NOTE: 29 USC 666(g) whoever knowingly makes any false statements, representation or certification in any application, record, plan or other documents filed or required to be maintained pursuant to the Act shall, upon conviction, be punished by a fine of not more than \$10,000 or by imprisonment of not more than 6 months or both.

POSTING: A copy of completed Corrective Action Worksheet should be posted for employee review

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 1 Item 1 Type of Violation: **Serious**

29 CFR 1926.102(a)(1): Eye and face protective equipment were not used when machines or operations presented potential eye or face injury from physical, chemical, or radiation agents:

On or about June 10, 2014, at the above addressed jobsite, employees using pneumatic nail guns and powered handheld circular saws did not wear safety glasses, thereby exposing employees to the hazards associated with eye injuries.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/07/2014
\$1320.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 1 Item 2 Type of Violation: **Serious**

29 CFR 1926.403(b)(1)(i): Safety of equipment was not determined on the basis of suitability of the equipment for an identified purpose as evidenced by listing, labeling, or certification for that identified purpose:

On or about June 10, 2014, at the above addressed jobsite, employees were exposed to electrical hazards associated with using a four outlet re-locatable power tap that was not approved for outdoor use.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/07/2014
\$3080.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 1 Item 3 Type of Violation: **Serious**

29 CFR 1926.404(b)(1)(i): Employer did not use either ground fault circuit interrupters as specified in paragraph (b)(1)(ii) of this section, or an assured equipment grounding conductor program as specified in paragraph (b)(1)(iii) of this section to protect employees on construction sites:

On or about June 10, 2014, at the above addressed jobsite, employees were exposed to electrical shock/electrocution hazards when using extension cords which were plugged in to a portable generator. A ground fault circuit interrupter was not used and the employer did not institute an assured equipment grounding conductor program.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/07/2014
\$3080.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 1 Item 4 Type of Violation: **Serious**

29 CFR 1926.416(e)(1): Worn or frayed electric cords or cables were used:

On or about June 10, 2014, at the above addressed jobsite, employees were using extension cords where the insulation was cracked and worn, exposing the conductors, exposing employees to electrical shock/electrocution.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/07/2014
\$3080.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 1 Item 5 Type of Violation: **Serious**

29 CFR 1926.451(b)(2): Scaffold platforms and walkways were not at least 18 inches wide:

On or about June 10, 2014, at the above addressed jobsite, employees were performing carpentry work from scaffold platforms that were ten (10) inches wide, exposing employees to falls of twelve (12) feet three (3) inches.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/07/2014
\$3080.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 1 Item 6 Type of Violation: **Serious**

29 CFR 1926.451(e)(1): When scaffold platforms were more than 2 feet (0.6 m) above or below a point of access, portable ladders, hook-on ladders, attachable ladders, stair towers (scaffold stairways/towers), stairway-type ladders (such as ladder stands), ramps, walkways, integral prefabricated scaffold access, or direct access from other scaffold, structure, personnel hoist, or similar surface was not used:

On or about June 10, 2014, at the above addressed jobsite, employees were not provided with a safe means of access to job-made scaffolds, exposing the employees to falls of twelve (12) feet three (3) inches.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/07/2014
\$3080.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 1 Item 7 Type of Violation: **Serious**

29 CFR 1926.451(g)(1): Each employee on a scaffold more than 10 feet above a lower level were not protected from falling to that lower level:

On or about June 10, 2014, at the above addressed jobsite, employees performing residential carpentry operations from a job-made scaffold, twelve (12) feet three (3) inches above the second floor, were exposed to injuries from falls.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/07/2014
\$3080.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 1 Item 8 Type of Violation: **Serious**

29 CFR 1926.454(a): The employer did not have each employee who performed work while on a scaffold trained by a person qualified in the subject matter to recognize the hazards associated with the type of scaffold being used and to understand the procedures to control or minimize those hazards:

On or about June 10, 2014, at the above addressed jobsite, employees were exposed to fall hazards while working from job-made scaffolds and were not provided with training to recognize and minimize those hazards.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/24/2014
\$2200.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

The alleged violations below have been grouped because they involve similar or related hazards that may increase the potential for injury or illness.

Citation 1 Item 9 a Type of Violation: **Serious**

29 CFR 1926.1052(c)(1)(i): Stairways having four or more risers or rising more than 30 inches (76 cm), whichever is less, were not equipped with at least one handrail:

On or about June 10, 2014, at the above addressed jobsite, employees were using a stairway not equipped with at least one handrail to access the second floor working area, thereby exposing employees to fall hazards.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/07/2014
\$2200.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 1 Item 9 b Type of Violation: **Serious**

29 CFR 1926.1052(c)(4): Mid-rails, screens, mesh, intermediate vertical members, or equivalent intermediate structural members were not provided between the top rail of the stair rail system and the stairway steps:

On or about June 10, 2014, at the above addressed jobsite, the stairway to the second floor was not provided with mid-rails, thereby exposing employees to fall hazards.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:

11/07/2014

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 2 Item 1 Type of Violation: **Willful**

29 CFR 1926.501(b)(13): Each employee(s) engaged in residential construction activities 6 feet (1.8 m) or more above lower levels are not protected by guardrail systems, safety net system, or personal fall arrest system, nor are employee(s) provided with an alternative fall protection measure under another provision of paragraph 1926.501 (b):

The employer does not protect each employee engaged in residential construction activities 6 feet or more above lower levels.

This most recently occurred on or about June 9, 2014 and June 10, 2014, at the above addressed jobsite. Employees are exposed to fall hazards while performing framing and carpentry operations on a residential property.

Instance 1: Employees constructing the ridge and rafters on a residential property are not protected from falling, exposing employees to a fall hazard of nineteen (19) feet.

Instance 2: Guardrails are missing from the second floor front windows while employees are lifting materials through the windows, exposing employees to a fall hazard of fourteen (14) feet two (2) inches.

Instance 3: Employees sheeting the second floor of a residential property are not protected from falling, exposing employees to a fall hazard of eleven (11) feet.

To abate this hazard in the future, the employer must ensure that fall protection equipment is available and used when employees are working at heights 6 feet or more above lower levels.



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

The employer has been cited for this practice that included: Bosco Custom Homes, Inc., was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.501(b)(13) which was contained in OSHA inspection number 815101, citation number 1, item number 2A, issued on March 13, 2013, and became final order on or about April 17, 2013, with respect to a workplace located at Ashwood Park, 4075 Teak Court, Lot 76, Naperville, IL 60565, and OSHA inspection number 864645, citation number 1, item number 1, issued on March 13, 2013, and became final order on or about April 17, 2013, with respect to a workplace located at 11514 S. Century, Plainfield, IL 60544, and OSHA inspection number 940669, citation number 2, item number 1, issued on October 22, 2013, and became final order on or about December 11, 2013, with respect to a workplace located at 741 Winged Elm, Elgin, IL 60120.

Pursuant to 29 CFR 1903.19, the employer must submit documents describing the steps it is taking to ensure compliance, including an explanation of how these steps protect its employees from falls.

Date By Which Violation Must be Abated:	11/07/2014
Proposed Penalty:	\$30800.00

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 3 Item 1 Type of Violation: **Repeat**

29 CFR 1926.100(a): Employees working in areas where there was a possible danger of head injury from impact, or falling or flying objects, or from electrical shock and burns, were not protected by protective helmets:

On or about June 10, 2014, at the above addressed jobsite, employees working below residential carpentry operations were not wearing hard hats to protect against falling materials and debris.

Bosco Custom Homes, Inc. was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.100(a), which was contained in OSHA inspection number 940669, citation number 1, item number 1, and was affirmed as a final order on December 11, 2013, with respect to a workplace located at 741 Winged Elm, Elgin, IL 60120.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/07/2014
\$4400.00

See pages 1 through 4 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

U.S. Department of Labor
Occupational Safety and Health Administration

Inspection Number: 980163
Inspection Date(s): 06/10/2014 - 06/11/2014
Issuance Date: 10/28/2014



Citation and Notification of Penalty

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187

Citation 3 Item 2 Type of Violation: **Repeat**

29 CFR 1926.503(a)(1): The employer did not provide a training program for each employee potentially exposed to fall hazards to enable each employee to recognize the hazards of falling and the procedures to be followed in order to minimize these hazards:

On or about June 10, 2014, at the above addressed jobsite, employees were exposed to falls while working on a residential property and were not provided with training to recognize and minimize the hazards associated with falls.

Bosco Custom Homes, Inc. was previously cited for a violation of this occupational safety and health standard or its equivalent standard 29 CFR 1926.503(a)(1), which was contained in OSHA inspection number 815101, citation number 1, item number 2b and was affirmed as a final order on April 17, 2013, with respect to a workplace located at Ashwood Park, 4075 Teak Court, Lot 76, Naperville, IL 60565.

Abatement documentation is required for this item in accordance with the requirements of 29 CFR 1903.19(d).

Date By Which Violation Must be Abated:
Proposed Penalty:

11/07/2014
\$4400.00

A handwritten signature in black ink, appearing to read "J. Scott", written over a horizontal line.

Jacob Scott
Area Director

U.S. Department of Labor
Occupational Safety and Health Administration
365 Smoke Tree Plaza
North Aurora, IL 60542
Phone: 630-896-8700 Fax: 630-892-2160



INVOICE / DEBT COLLECTION NOTICE

Company Name: Bosco Custom Homes, Inc.
Inspection Site: 226 E. Parkway Dr., Wheaton, IL 60187
Issuance Date: 10/28/2014

Summary of Penalties for Inspection Number	980163
Citation 1, Serious	\$24200.00
Citation 2, Willful	\$30800.00
Citation 3, Repeat	\$8800.00
TOTAL PROPOSED PENALTIES	\$63800.00

To avoid additional charges, please remit payment promptly to this Area Office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: "DOL-OSHA". Please indicate OSHA's Inspection Number (indicated above) on the remittance. You can also make your payment electronically on www.pay.gov. On the left side of the pay.gov homepage, you will see an option to Search Public Forms. Type "OSHA" and click Go. From the results, click on **OSHA Penalty Payment Form**. The direct link is <https://www.pay.gov/paygov/forms/formInstance.html?agencyFormId=53090334>. You will be required to enter your inspection number when making the payment. Payments can be made by credit card or Automated Clearing House (ACH) using your banking information. Payments of \$50,000 or more require a Transaction ID, and also must be paid using ACH. If you require a Transaction ID, please contact the OSHA Debt Collection Team at (202) 693-2170.

OSHA does not agree to any restrictions or conditions or endorsements put on any check, money order, or electronic payment for less than the full amount due, and will cash the check or money order as if these restrictions or conditions do not exist.

If a personal check is issued, it will be converted into an electronic fund transfer (EFT). This means that our bank will copy your check and use the account information on it to electronically debit your account for the amount of the check. The debit from your account will then usually occur within 24 hours and will be shown on your regular account statement. You will not receive your original check back. The bank will destroy your

original check, but will keep a copy of it. If the EFT cannot be completed because of insufficient funds or closed account, the bank will attempt to make the transfer up to 2 times.

Pursuant to the Debt Collection Act of 1982 (Public Law 97-365) and regulations of the U.S. Department of Labor (29 CFR Part 20), the Occupational Safety and Health Administration is required to assess interest, delinquent charges, and administrative costs for the collection of delinquent penalty debts for violations of the Occupational Safety and Health Act.


Interest: Interest charges will be assessed at an annual rate determined by the Secretary of the Treasury on all penalty debt amounts not paid within one month (30 calendar days) of the date on which the debt amount becomes due and payable (penalty due date). The current interest rate is one percent (1%). Interest will accrue from the date on which the penalty amounts (as proposed or adjusted) become a final order of the Occupational Safety and Health Review Commission (that is, 15 working days from your receipt of the Citation and Notification of Penalty), unless you file a notice of contest. Interest charges will be waived if the full amount owed is paid within 30 calendar days of the final order.

Delinquent Charges: A debt is considered delinquent if it has not been paid within one month (30 calendar days) of the penalty due date or if a satisfactory payment arrangement has not been made. If the debt remains delinquent for more than 90 calendar days, a delinquent charge of six percent (6%) per annum will be assessed accruing from the date that the debt became delinquent.

Administrative Costs: Agencies of the Department of Labor are required to assess additional charges for the recovery of delinquent debts. These additional charges are administrative costs incurred by the Agency in its attempt to collect an unpaid debt. Administrative costs will be assessed for demand letters sent in an attempt to collect the unpaid debt.



Jacob Scott
Area Director


Date